

## **GENERAL NOTES:**

- 1. POST TYPE HYDRANT IS A SPECIAL USE HYDRANT AND SHALL NOT BE USED FOR FIRE FIGHTING.
- 2. ALL RECLAIMED HYDRANTS SHALL BE PAINTED
- PURPLE (PANTONE 521 OR 525).

  3. COMPLY WITH REQUIREMENTS OF AWWA C-502, DRY BARREL FIRE HYDRANTS AND AWWA C-550, PROTECTIVE EPOXY INTERIOR COATINGS FOR VALVES AND HYDRANTS.

## CONSTRUCTION KEY NOTES:

- A. OPERATING NUT NATIONAL STANDARD PENTAGON MEASURING 11/2" FROM POINT TO FLAT.
- B. ONE 2½" HOSE NOZZLE.
- C. 21/4 MAIN VALVE.
  D. 2" HYDRANT ELBOW.

**STANDARD DETAIL** 

DATE: 9/6/2006 REV: 5/10/2017 RECLAIMED WATER HYDRANT (POST TYPE HYDRANT)

