


**EL PASO WATER UTILITIES  
PUBLIC SERVICE BOARD****ADDENDUM NO. 1****FOR****CORRUGATED METAL PIPE CONDITION ASSESSMENT AND REPLACEMENT  
PROGRAM****PIEDRAS STREET; CYPRESS AVENUE SOUTH ALLEY TO PAISANO DRIVE****BID NO. SW36-23****JUNE 12, 2023**

In accordance with the Instruction to Bidders of the Contract Documents, the following revision to the Plans and/or Specifications shall become part of the Contract Documents and the Bidders shall acknowledge receipt thereof on their Bid Proposal.

**EL PASO WATER UTILITIES****BROWN AND CALDWELL**

Mirtha Solis  
Senior Purchasing Agent  
June 12, 2023



THE SEAL APPEARING ON THIS  
DOCUMENT WAS AUTHORIZED BY JOSEPH  
MORENO, P.E. 106186 ON JUNE 9, 2023.

Joseph Moreno, P.E.  
Engineer of Record  
Brown and Caldwell F-2139  
June 12, 2023

\*The EPWater representative's signature certifies that this Document shall become part of the Contract Documents for the referenced project. The signature is not a representation that the content of this document is technically correct.

Receipt of this Addendum must be acknowledged in writing to El Paso Water Utilities as required by the bid documents.

### **SUBMITTED QUESTIONS AND ANSWERS**

The following are answers to questions that were received prior to the cutoff date for questions.

Q-1.01. For the material on this project is only CMP and RCP accepted or can it be HDPE?

A-1.01 Only RCP is acceptable pipe material for replacement of the Storm Drain per Section 01 11 00, 1.02 and Section 33 05 45. CMP and HDPE pipe will not be accepted as alternative materials.

**\*\*\*END OF ADDENDUM NO. 1\*\*\***