

**EL PASO WATER
PURCHASING DEPARTMENT
1154 HAWKINS BLVD.
EL PASO, TEXAS 79925**

**CARTRIDGE FILTERS
71-23**

ADDENDUM 1

September 27, 2023

Attention of all bidders is directed to the following addendum to this Bid Proposal:

A. Response(s) to Bidder's question(s):

Question #1:

In regards to Bid Number: 71-23, Cartridge Filters, I would like to request that IAPMO be added to the list of approved accredited laboratories on section 2.3 CERTIFICATION REQUIREMENTS.

Yes, that will be acceptable

Question #2:

We would like to know El Paso Water's current price for:

Line Item #3 – 1-micron cartridge element, and

Line Item #4 – 5-micron cartridge element.

Line Item #3- \$3.62

Line Item #4- \$3.62

Question #3:

Could you confirm the Line Item 1 & 2 filter as a 3M model 740-KF? This is an oil field application filter and is not NSF.

3M 740 Series Filter Cartridge Model # 740K40PP015D1

Question #4:

Please provide more information on part numbers below. Manufacturer or description, will help.

EA	174	10-MICRON CARTRIDGE FILTERS (MODEL 740KF) OR EQUIVALENT
EA	2722	15-MICRON CARTRIDGE FILTERS (MODEL 740KF) OR EQUIVALENT
EA	9560	1-MICRON CARTRIDGE FILTERS (MODEL 01-30) OR EQUIVALENT
EA	16600	5-MICRON CARTRIDGE FILTERS (MODEL 05-40) OR EQUIVALENT

Line Item 1 & 2 (10um & 15um Filters) 3M 740 Series Cartridge Filters
Line Item 3 & 4 (1um & 5um Filters) Suez MuniZs Cartridge Filters

Question #5:

Can an estimated order schedule and/or minimum order size be defined for the four different line items?

No. It is dependent on production and how many times we start and stop a well, the quality of a particular well and so forth. Use of the wells increases when the surface water season ends. Surface water season is driven by availability of water at Elephant Butte. The normal season is March -October. However, with the recent droughts we have had as little as 6 weeks of surface water.

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their bid submittal. Failure to acknowledge addendum(s), may result in rejection of bid.



Barbara Logan
Procurement Analyst



Rosemary Guevara
Purchasing & Contracts Manager

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT

**The signature of the EPWater Purchasing Staff certifies only that this document shall become part of the Contract Documents for the referenced project and is NOT a representation that the content of this document is technically correct.*