

MINIMUM REQUIREMENTS FOR UTILITY PLANS NEW SERVICES INSTALLATIONS

For commercial / Industrial / Apartments

Must be appear:

- North arrow
- Official address
- Street names or indicate if within alley
- Property line
- Include underground services that could prevent us from performing the installation correctly
- The existing sewer main and/or water main to which your services will be connected
- Sewer and/or water services must be perpendicular to sewer main
- Meter must be located outside the property behind curb, within parkway/sidewalk
- Backflows must be adjacent to the meter, in line with the service line and in direct sight in private property line
- The types and sizes of meters to be used must be indicated
- Type and models of backflows to be used must be indicated. Submittals need to be provided
- Notes must state that El Paso Water to make connections to existing water and/or sewer public mains